


Loss Prevention Certification Board



CERTIFICATE OF PRODUCT CONFORMITY

This is to certify

CONTROL EQUIPMENT LIMITED

Hillcrest Business Park, Cinderbank, Dudley, West Midlands DY2 9AP

has complied with the requirements identified in

**LPS 1054 : Issue 1 – Requirements for the evaluation of
Component compatibility for fire alarm systems**

and is authorised to use the LPCB mark on

Precept fire alarm system

(Refer to attached Appendix for details)

Certificate No. 018b Issue 5

Issued 16 January 2003

Valid Until 15 January 2006

Signed on behalf of the LPCB

E MATTIE-SULEIMAN




This Certificate is issued and held in force subject to the corresponding ISO 9000 certificate being maintained.

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel 01923 664100 Fax 01923 664603 www.brecertification.co.uk

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

To check the authenticity of this certificate, please visit our website or contact us.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE OF PRODUCT CONFORMITY NO. 018b

CONTROL EQUIPMENT LIMITED

Certificated Product

LPCB Ref. No.

Precept fire alarm system

018b/S1

Comprising the following products:

Control Equipment Ltd.

Precept 2, 4, 8, 16 and 32 zone control and indicating equipment

Apollo Fire Detectors Ltd.

53531-221 grade 1 rate of rise heat detector (45681-007 base)
53531-151 ionisation smoke detector (45681-007 base)
53531-201 photoelectric smoke detector (45681-007 base)
55000-100 grade 1, rate of rise heat detector (45681-200 base)
55000-101 grade 2, rate of rise heat detector (45681-200 base)
55000-102 grade 3, rate of rise heat detector (45681-200 base)
55000-103 range 1, rate of rise heat detector (45681-200 base)
55000-104 range 2, rat of rise heat detector (45681-200 base)
55000-200 ionisation smoke detector (45681-200 base)
55000-210 integrating ionisation smoke detector (45681-200 base)
55000-300 photoelectric smoke detector (45681-200 base)

Hochiki Corporation

DFE-60 grade 2 fixed temperature heat detector (YBF-RL/4H5 base)
SLK-E photoelectric smoke detector (YBF-RL/4H5 base)
SIH-E ionisation smoke detector (YBF-RL/4H5 base)
DFE-90 range 1 fixed temperature heat detector (YBF-RL/4H5 base)
DCC-1EL grade 1 rate of rise heat detector (YBF-RL/4H5 base)
DCC-2EL grade 2 rate of rise heat detector (YBF-RL/4H5 base)
DCC-R1EL range 1 rate of rise heat detector (YBF-RL/4H5 base)


Signed on behalf of the LPCB

Appendix Issue No. 5
Page 1 of 2

E MATTIE-SULEIMAN

Issued 16 January 2003
Valid Until 15 January 2006

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE OF PRODUCT CONFORMITY NO. 018b

CONTROL EQUIPMENT LIMITED

Certificated Product

Precept fire alarm system (cont'd.).

LPCB Ref. No.

018b/S1

Hochiki Europe (UK) Ltd.

SLK-E photoelectric smoke detector (YBF-RL/4H5 base)

SIH-E ionisation smoke detector (YBF-RL/4H5 base)

KAC Alarm Company Ltd.

KR72 indoor manual call point.

Photain Controls Ltd.

ISD-P91 ionisation smoke detector (FSB-P91 base)

PRR-P91 grade 1 rate of rise heat detector (FSB-P91 base)

PRR-P91 range 1 fixed temperature heat detector (FSB-P91 base)

Signature Industries Ltd. - Clifford and Snell Alarms

MCP/R/F manual call point

MCP/R/S manual call point

System Sensor, St. Charles, Illinois, USA

1151E ionisation smoke detector (B401 base)

2151E photoelectric smoke detector (B401 base)

Signed on behalf of the LPCB

E MATTIE-SULEIMAN

Appendix Issue No.

5

Page

2 of 2

Issued

16 January 2003

Valid Until

15 January 2006

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel 01923 664100 Fax 01923 664603 www.brecertification.co.uk

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions

and is maintained and held in force through regular surveillance activities.

To check the authenticity of this certificate, please visit our website or contact us.